



# Tripura Natural Gas Company Limited

(A Joint Venture of GAIL (India) Ltd., Govt. of Tripura and Govt. of Assam)

Shilpa Nigam Bhawan, Khejur Bagan, P.O – Kunjaban Agartala, Tripura-799006

Agartala, Tripura-799006

CIN: U23201TR1990SGC003451

## Bidders Query & Reply

Date: 28/01/2019

**Name of Work** – Procurement of SS Tubes for CNG Stations

**E - Tender No** - TNGCL/C&P/Expn. Project/SS Tube/P(105)/2018-19

Sl. No	Type of Query	Bidders Query	Clarification / Reply From TNGCL
1	Technical	The tubes must be proven track record and is supported by end-user CGD company certificate for a min period of 3 years usage, instead of just a supply reference and not used or proven, Therefore, we request you to make the corrigendum accordingly	Tender Condition Prevails
2	Technical	You are aware that the tubes used for CNG is getting manufactured regularly as per ASTM A269 and not made to order. Normally, all the leading overseas manufacturers is being an integrated process of manufacturing right from melting of steel to the end product, the quality checking process is totally in house and the MTC confirms and qualifies all parameters of QAP. The inspection will be at our warehouse- Kandla Gujarat of Tubacex which will be only review of MTC as executed for all your past orders.	Tender Condition Prevails
3	Technical	As per ASTM A269 the Minimum Molybdenum percentage required is 2% and not 2.5%	Refer Corrigendum
4	Commercial	Bid Due date Extension up-to 15/02/2019	Refer Corrigendum

\*\*\* Rest of the Terms & Conditions shall be remaining Unchanged.

For on Behalf of TNGCL  
(C. Ghosh)  
Dy. Manager (C&P)



# Tripura Natural Gas Company Limited

(A Joint Venture of GAIL (India) Ltd., Govt. of Tripura and Govt. of Assam)  
Shilpa Nigam Bhawan, Khejur Bagan, P.O – Kunjaban Agartala, Tripura-799006

CIN: U23201TR1990SGC003451

## Corrigendum # 1

**Name of Work** – Procurement of SS Tubes for CNG Stations

**E - Tender No** - TNGCL/C&P/Expn. Project/SS Tube/P(105)/2018-19

Sl. No	Type of Query	Bidders Query	Addendum
1	Commercial	Bid Due date Extension	Bid due date has been extended. The last date of bid submission is on <b>05/02/2019</b> at <b>15:00</b>
2	Technical	As per ASTM A269 the Minimum Molybdenum percentage required is 2% and not 2.5%	As per ASTM A269 Minimum Molybdenum percentage required is 2% to 3%

*Rest of the Terms & Conditions shall be remaining Unchanged*

For on Behalf of TNGCL  
(C.Ghosh)  
Dy. Manager (C&P)

Date : 28/01/2019